



## SARASOTA COUNTY

"Dedicated to Quality Service"

## Permit to Remove Backflow Preventer

November 30, 2006

PASCHAL PROP INC  
997 PASCHAL PL  
SARASOTA, FL 34232  
Serial# 79569 Meter# 59378435

Dear Customer:

To be consistent with ordinance 89-19 and the Cross Connection Control Handbook, which states on page 15, section III, B.2 If the water purveyor determines that a potential cross-connection condition exists, the water purveyor shall establish a hazard level commensurate with the degree of that hazard level utilizing AWWA standards as minimum guidelines, and require a specific type of backflow preventer for the premises.

On November 11, 2006, the Sarasota County Cross-Connection Control Coordinator did a survey on the property at 997 PASCHAL PL and found there to be no hazard or potential for a hazard which would require a backflow assembly. With that conclusion, you are permitted to have your backflow assembly removed from your property. If for any reason, a potential hazard should occur, then you will be obligated to have a backflow assembly re-installed.

If you have any additional questions about backflow preventers or cross-connection control, contact the Sarasota County Call Center at 941-861-5000 and ask for backflow prevention.

Sincerely,

Douglas E. Bailey  
Cross-Connection Control Coordinator  
Sarasota County Utilities

Kevin Oatman  
Environmental Inspector  
Sarasota County Utilities