

**POST RETROFIT
DUCT TEST REPORT**



get
ENERGYsmart

RETROFIT PROGRAM

Submission of this form as an attachment to the Rebate Request Form is required in order to qualify for the duct repair rebate under the Get Energy Smart Retrofit Program. This test must be performed by a Class 1 Florida certified Energy Rater, Florida licensed Mechanical Contractor, or certified Test and Balance Agent. The cost for this test should be included in the initial estimate provided to the customer by the Participating Contractor providing the duct repair.

Owner: _____

Address: _____

CFM25 Air Distribution System Leakage Test Values		
Line	System	Duct Leakage
1	System 1	_____cfm25 (out or tot)
2	System 2	_____cfm25 (out or tot)
3	System 3	_____cfm25 (out or tot)
4	System 4	_____cfm25 (out or tot)
5	Total House Duct System Leakage	Sum lines 1-4 _____ Divide by _____ = _____ (Qn, out or tot) (total conditioned floor area) To qualify for the Duct Repair/Sealing Program, Qn (out or tot) must be less than or equal to 0.06.

I hereby certify that the above duct testing has been performed in accordance with ASTM Standard E1554, Method A or Method D.

Signature: _____

Printed Name: _____

Rater Certification #: _____

(or) Mechanical License #: _____

(or T&B Certification #: _____

Date: _____

Certified Florida Class 1 raters can be found at <http://energygauge.com/search.htm>

